

Request for Quotes

Steel Poles

Summary and Technical Specifications:

OMPA is requesting quotes for steel poles to be delivered to 3 sites in the State of Oklahoma. All poles shall be designed for direct embedment. Poles shall be hot dip galvanized with a welded butt plate and top cap. A suitable **UV stabilized** below grade coating of at least 20 mils shall be applied based on the height of the poles and expected burial depth (10% of the pole length plus 2'). Jacking nuts and 18 pre-drilled holes per pole shall be provided. Zinc coated grounding inserts shall be included.

Bids are due March 29, 2018 4:00pm Central Time.

Specific details of quote request:

- a) **Steel Poles and delivery** **Expected delivery date** _____ **Price \$**_____
- a. Quantity two (2) 50' H1 class steel poles to be delivered to Okeene, OK
 - b. Quantity six (6) 65' H1 class steel poles to be delivered to Wetumka, OK
 - c. Quantity one (1) 50' H1 class steel pole to be delivered to Waynoka, OK
 - d. Quantity fifteen (15) 65' H1 class steel poles to be delivered to Waynoka, OK

B. I certify, if awarded the contract, whether competitively bid or not, neither the contractor nor anyone subject to the contractor's direction or control has paid, given or donated or agreed to pay, give or donate to any officer or employee of the State of Oklahoma or the Oklahoma Municipal Power Authority any money or other thing of value, either directly or indirectly, in procuring the contract to which this statement is attached.

Signature

Printed Name

Subscribed and sworn to before me this _____ day of _____, 20 _____.

Notary Public

My Commission Expires:
